



14"

23"

HWF - 4923XHC

Sediment, Chlorine & Cyst Reduction

SPECIFICATIONS

Capacity:	265,000 Gallons
Flow Rate:	7.5 GPM
Micron Rating:	0.2 Micron
Operating Pressure:	20-125 PSI
Operating Temperature:	35°-100° F

Flow rate and filter capacity refer to the individual filter only. For systems containing multiple filters, refer to the system installation manual for specifications.

Replace the cartridge every 24 months to ensure proper filter performance. The cartridge capacity may vary according to flow rate, inlet line pressure and local water conditions, which may require more frequent cartridge replacement.

Check for compliance with state and local laws and regulations. Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. The contaminants or substances reduced by this filter are not necessarily in your water. For additional product information, please visit www.honestwaterfilter.com.

To be serviced by an authorized licensed plumbing professional only.



NSF
Tested and Certified by NSF International
against NSF/ANSI Standard 42 for the
reduction of chlorine taste and odor.



The Honest Water Filter Company
P.O. Box 2388 • Ramona, CA 92065
Telephone (808) 842-4224
www.honestwaterfilter.com
P/N 900903 | EPA Est. No. 92705

Date Installed

HWF - 4923XHC

Sediment, Chlorine & Cyst Reduction

SPECIFICATIONS

Capacity:	265,000 Gallons
Flow Rate:	7.5 GPM
Micron Rating:	0.2 Micron
Operating Pressure:	20-125 PSI
Operating Temperature:	35°-100° F

Flow rate and filter capacity refer to the individual filter only. For systems containing multiple filters, refer to the system installation manual for specifications.

Replace the cartridge every 24 months to ensure proper filter performance. The cartridge capacity may vary according to flow rate, inlet line pressure and local water conditions, which may require more frequent cartridge replacement.

Check for compliance with state and local laws and regulations. Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. The contaminants or substances reduced by this filter are not necessarily in your water. For additional product information, please visit www.honestwaterfilter.com.

To be serviced by an authorized licensed plumbing professional only.



NSF
Tested and Certified by NSF International
against NSF/ANSI Standard 42 for the
reduction of chlorine taste and odor.



The Honest Water Filter Company
P.O. Box 2388 • Ramona, CA 92065
Telephone (808) 842-4224
www.honestwaterfilter.com
P/N 900903 | EPA Est. No. 92705

Date Installed

04092019 0120005